



JO-BELL PRODUCTS
DIVISION OF DALNOR SYSTEMS, INC

711 Corsair Drive Bonham, TX 75418
Ph 903.486.6982 Fx: 903.486.6985

GENERAL INSTALLATION INSTRUCTIONS

MODEL OF SWITCH ASSEMBLY

Switch hook-up leads are provided and might be marked:

“C” (Common)
“NO” (Normally Open)
and “NC” (Normally Closed)

Wire color might also identify the leads:

BLACK wire (Common)
RED wire (Normally Open)
and WHITE wire (Normally Closed).

End user will need to use female quick disconnect lugs to terminate wire. Part number 2-520184-2, Mfr TE Connectivity will be provided.

Installation of switch is accomplished by loosening the #8 nut located on the clamp positioned above the micro switch. Full detachment of the nut is not necessary. Once the clamp has expanded sufficiently, slide the switch operator, base side down, over the top of the tubing in the enclosure. Adjust the position of the assembly on the tubing to match the actuation point. Tighten the #8 nut to complete installation.